


LAST REV.	DATE	DESCRIPTION



**NOTES:**

1. MOUNTING FLANGES MUST BE SEALED WITH CAULK OR SEALANT CONTINUOUSLY W/O VOIDS
2. MIST ELIMINATOR UNIT MUST BE VERTICAL OR HAVE TOP EDGE CANTED OUTBOARD FOR BEST PERFORMANCE

TITLE:

SCALE: NA

SERIAL #: XXX-XXXX

TOTAL QUANTITY 1

**OUTSIDE FACE DRAIN MOISTURE ELIMINATOR**

PAGE 1 OF 1 PAGES

CUSTOMER NAME:

Livos Technologies, LLC.

ORDER #: XXX-XX-XXX

**LIVOS TECHNOLOGIES, LLC.**

DATE: 12-14-2006

3201 SE RAILROAD AVE.  
STUART, FL 34997 U.S.A.

DWG #:

TEL. 772-220-1524 FAX. 772-220-1524